

ANALYTICAL REPORT

February 02, 2022

Work Order: 1FB0052

Page 1 of 3

Report To
Diana Johnson City of Lee's Summit - Public Works Dept. 220 SE Green Str Lees Summit, MO 64063

Work Order Information
Date Received: 02/01/2022 10:47AM Collector: Client Phone: (816) 969-7428 PO Number: Routine Analysis

Project : Emery Sapp & Sons

Project Number: Osage 3rd Plat

Analyte		Result	MRL	Batch	Method	Analyst	Analyzed	Qualifier
1FB0052-01 North 8in					Matrix:Drink Wtr		Collected: 02/01/22 07:57	
Total Coliforms		<1.0 MPN/100ml	1.0	1FB0052	9223B-QT	CLJ	02/01/22 16:50	
E. Coli		<1.0 MPN/100ml	1.0	1FB0052	9223B-QT	CLJ	02/01/22 16:50	
1FB0052-02 South 6in					Matrix:Drink Wtr		Collected: 02/01/22 08:01	
Total Coliforms		<1.0 MPN/100ml	1.0	1FB0052	9223B-QT	CLJ	02/01/22 16:50	
E. Coli		<1.0 MPN/100ml	1.0	1FB0052	9223B-QT	CLJ	02/01/22 16:50	

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety. Samples were preserved in accordance with 40 CFR for pH adjustment unless otherwise noted. MRL= Method Reporting Limit.

City of Lee's Summit - Public Works Dept.
220 SE Green Str
Lees Summit, MO 64063

February 02, 2022

Page 2 of 3

Work Order: 1FB0052

Certified Analyses included in this Report

Method/Matrix	Analyte	Certifications
9223B-QT in Drink Wtr		
	Total Coliforms	KS-KC,MO-KC
	E. Coli	KS-KC,MO-KC

Code	Description	Number	Expires
KS-KC	Kansas Department of Health and Environment-KC	E-10110	04/30/2022
KS-NT	Kansas Department of Health and Environment (NELAP)	E-10287	10/31/2022
MO-KC	Missouri Department of Natural Resources	140	04/30/2022
SIA1X	Iowa Dept. of Natural Resources (updated certificate pending)	95	02/01/2024

End of Report



Keystone Laboratories, Inc.

Carolyn Jackson
Project Manager

Keystone

205 E VanBuren St
Centerville, IA 52544
Phone: 641-437-7023
Fax: 641-437-7040

PAGE _____ OF _____

FORM: CCR 7-97