

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215946
Address: 2112 SW HARVEST MOON LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|------------------------|------------------|----------|---------------------------|
| Erosion Control | Mitchell Schwarz | Failed | Monday, February 14, 2022 |

Corrective Action Required:

| | | |
|---|------|--|
| 1 | Misc | -Repair Downed silt fence -maintain gravel filter |
|---|------|--|

Corrective Action Required:

| | | |
|---|---|---|
| 2 | DCM1 ESC REQUIRED NO FURTHER INSP | EROSION CONTROL REQUIRED. NO FURTHER INSPECTIONS WILL BE PERFORMED UNTIL EROSION CONTROL IS INSTALLED AND IN COMPLIANCE. |
|---|---|---|

Corrective Action Required:

| | | |
|---|----------------------------|---|
| 3 | DCM3 ESC REQUIRED 2 DAY | EROSION CONTROL REQUIRED. EROSION CONTROL SHALL BE IN COMPLIANCE WITHIN TWO BUSINESS DAYS. |
|---|----------------------------|---|

Comments: