CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20214591

Address: 1103 SW OLDHAM PKWY, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Site Visit Ronald Paynter Partial Monday, February 14,

2022

Corrective Action Required:

1 Misc Found out they formed and poured curbing without inspections. No geogrid

was placed under curb line. No proof roll was done on the curb line either. They curb line along the asphalt section of the parking lot has to be removed

and replaced properly. RP 12-20-21

Informational:

2 Misc Stopped by the job site today. No work was being done outside, but a

contractor that was working inside came out to see me. He thought I was the

building inspector. RP 2-1-22

Informational:

3 Misc No exterior work being done today that requires inspections by me. RP

2-10-22

Informational:

4 Misc Plumber started installation of a grinder pump for the sanitary service line.

Called around to verify who looks at what concerning the pump. It was determined that the building inspector would look at the pump, while the field inspector will look at the connection to the service lateral. RP 2-11-22

Comments: