

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210774

Address:

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Shawn Hoffman	Failed	Monday, February 14, 2022

Corrective Action Required:

- | | | |
|---|--------------------------|--|
| 1 | Miscellaneous Correction | <ul style="list-style-type: none">- Maintain erosion control- Driveway inspection incomplete- install irrigation system- Complete gutters- Final grading and sod- Provide ladder for both basement Egress windows- Seal top of meter can- Seal top of A/C disconnect- Seal penetration on exterior- Sump discharge 36" from foundation- Break off set screw on back flow device in garage- Make access panel for water and sewer in garage- Add missing joist hangers garage landing- Connect water heater in apartment over garage |
|---|--------------------------|--|

Comments: