

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20220024
Address: 2104 NW SHAMROCK AVE, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|-----------------|----------|---------------------------|
| All Rough Inspection - Residential | Michael Harkins | Failed | Monday, February 14, 2022 |

| | |
|---------------------------------|---|
| Corrective Action Required: | |
| 1 Miscellaneous Correction | FIREBLOCK VERTICAL TO HORIZONTAL AT EGRESS WINDOW PROVIDE VERTICAL FIREBLOCKING EVERY 10' AT FURR OUT FIREBLOCK / INSULATE BEAM POCKET BASEMENT BEDROOM |

Comments: