

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20213319  
Address: 1418 SW GEORGETOWN DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Control</b>	Patrick Schonfeldt	Failed	Monday, February 14, 2022

Corrective Action Required:

1	DCM1 ESC REQUIRED NO FURTHER INSP	Inspection Denied  -Maintain erosion control on lot, maintain silt fence at front of lot, erosion control required at rear of lot to protect creek, remove construction trash and debris from creek/tree line rear of lot -Maintain the gravel filter on drive, min 6" lift with gravel -Have complete city stamped set of plans on site, plans on site have torn pages and missing pages  Correct all issues above before rescheduling an inspection
---	---	---

**Comments:**