

ANALYTICAL REPORT

February 02, 2022

Work Order: 1FB0053

Page 1 of 3

| Report To |
|---|
| Diana Johnson City of Lee's Summit - Public Works Dept. 220 SE Green Str Lees Summit, MO 64063 |

| Work Order Information |
|--|
| Date Received: 02/01/2022 10:47AM Collector: Client Phone: (816) 969-7428 PO Number: Routine Analysis |

Project : Redford Construction

Project Number: Summit View Farms 4th Plat

| Analyte | Result | MRL | Batch | Method | Analyst | Analyzed | Qualifier |
|-------------------|----------------------|-----|---------|------------------|---------|---------------------------|-----------|
| 1FB0053-01 | North (Enoch St) | | | Matrix:Drink Wtr | | Collected: 02/01/22 09:45 | |
| Total Coliforms | <1.0 MPN/100ml | 1.0 | 1FB0052 | 9223B-QT | CLJ | 02/01/22 16:50 | |
| E. Coli | <1.0 MPN/100ml | 1.0 | 1FB0052 | 9223B-QT | CLJ | 02/01/22 16:50 | |
| 1FB0053-02 | South (Setena Place) | | | Matrix:Drink Wtr | | Collected: 02/01/22 09:40 | |
| Total Coliforms | <1.0 MPN/100ml | 1.0 | 1FB0052 | 9223B-QT | CLJ | 02/01/22 16:50 | |
| E. Coli | <1.0 MPN/100ml | 1.0 | 1FB0052 | 9223B-QT | CLJ | 02/01/22 16:50 | |

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety. Samples were preserved in accordance with 40 CFR for pH adjustment unless otherwise noted. MRL= Method Reporting Limit.

City of Lee's Summit - Public Works Dept.
220 SE Green Str
Lees Summit, MO 64063

February 02, 2022

Page 2 of 3

Work Order: 1FB0053

Certified Analyses included in this Report

| Method/Matrix | Analyte | Certifications |
|-----------------------|-----------------|----------------|
| 9223B-QT in Drink Wtr | | |
| | Total Coliforms | KS-KC,MO-KC |
| | E. Coli | KS-KC,MO-KC |

| Code | Description | Number | Expires |
|-------|---|---------|------------|
| KS-KC | Kansas Department of Health and Environment-KC | E-10110 | 04/30/2022 |
| KS-NT | Kansas Department of Health and Environment (NELAP) | E-10287 | 10/31/2022 |
| MO-KC | Missouri Department of Natural Resources | 140 | 04/30/2022 |
| SIA1X | Iowa Dept. of Natural Resources (updated certificate pending) | 95 | 02/01/2024 |

End of Report



Keystone Laboratories, Inc.

Carolyn Jackson
Project Manager

Keystone

205 E VanBuren St
Centerville, IA 52544
Phone: 641-437-7023
Fax: 641-437-7040

Page 3 of 3

(If Applicable)

100