



Aspen Homes Mail - City comment...



Trevor Wiest <trevor@aspenhomeskc.com>

City comment via Plan Review

Jeff Wilp <jeffw@mcdfurnace.com>

Mon, Feb 14, 2022 at 3:06 PM

To: Trevor Wiest <trevor@aspenhomeskc.com>

No need for combustion air. It get 100% of combustion from outside

Sent from my T-Mobile 5G Device

Get [Outlook for Android](#)

From: Trevor Wiest <trevor@aspenhomeskc.com>

Sent: Monday, February 14, 2022 2:53:34 PM

To: Jeff Wilp <jeffw@mcdfurnace.com>

Subject: City comment via Plan Review

Hey Jeff,

The city made a comment for combustion air calculations. I attached their comment and the set of build plans.

Since we're installing 95% efficiency furnaces, do we need these calculations if it pulls in outside air?

Thanks for the help!

--

Trevor Wiest
Aspen Homes
816.728.9115