

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20211738
Address: 2061 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sanitary Sewer Construction Inspection	Ronald Paynter	Passed	Tuesday, February 15, 2022

Informational:
1 Misc Sanitary connections coming out of the building and grease interceptor are connected with hard back Fernco's. RP 8-23-21

Informational:
2 Misc They tied into the sanitary main line with a Max Adapter coupler. They are closer to the manhole than the design calls for. RP 8-24-21

Comments: