

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20210354

Address: 2101 SW M 150 HWY, LEES SUMMIT, MO 640823902 SW PRYOR RD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                          | Inspector:    | Outcome: | Date:                      |
|--------------------------------------|---------------|----------|----------------------------|
| <b>Water Line - Hydrostatic Test</b> | Diana Johnson | Passed   | Tuesday, February 15, 2022 |

Informational:

|   |      |                                                                                         |
|---|------|-----------------------------------------------------------------------------------------|
| 1 | Misc | On 12/8/2021 Hydrostatic Pressure test entire system and it held for 2 hours @ 155 psi. |
|---|------|-----------------------------------------------------------------------------------------|

**Comments:**