

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20211738
Address: 2061 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pavement-Aggregate Base	Ronald Paynter	Partial	Tuesday, February 15, 2022

Informational:		
1	Misc	KAW Valley rolled out Tenax 302 geo grid and covered it with 6 inches of APWA Type 3 rock. So far they've laid out 115 tons of AB3. RP 11-9-21
Informational:		
2	Misc	Kaw Valley rolled out more Tenax 302 and covered it with more AB3 rock. RP 11-17-21
Informational:		
3	Misc	Kaw Valley still rolling on geogrid and laying down AB3 for the parking lot subgrade. RP 2-15-22

Comments: