

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20216178
Address: 211 NW CARSON DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pool Steel/Bonding - Residential	Shawn Hoffman	Failed	Tuesday, February 15, 2022

Informational:

1	Miscellaneous Correction	Grounding for shell only. Pool has 4 bonding points and hot tub has 2 additional
---	--------------------------	--

Corrective Action Required:

2	Misc	-no bond to rebar - no bond back to pumps - not complete
---	------	--

Comments: