

ANALYTICAL REPORT

December 23, 2021

Work Order: 1EL2092

Page 1 of 3

Report To
Tom Taylor City of Lee's Summit - Public Works Dept. 220 SE Green Str Lees Summit, MO 64063

Work Order Information
Date Received: 12/22/2021 1:28PM Collector: Client Phone: (816) 969-7428 PO Number: Routine Analysis

Project : Emery Sapp & Sons

Project Number: Osage PH II/ 2nd Plat

Analyte	Result	MRL	Batch	Method	Analyst	Analyzed	Qualifier
1EL2092-01 Osage Dr				Matrix:Drink Wtr		Collected: 12/22/21 09:23	
Total Coliforms	<1.0 MPN/100ml	1.0	1EL1186	9223B-QT	CLJ	12/22/21 16:45	
E. Coli	<1.0 MPN/100ml	1.0	1EL1186	9223B-QT	CLJ	12/22/21 16:45	
1EL2092-02 Osage Dr				Matrix:Drink Wtr		Collected: 12/22/21 09:27	
Total Coliforms	<1.0 MPN/100ml	1.0	1EL1186	9223B-QT	CLJ	12/22/21 16:45	
E. Coli	<1.0 MPN/100ml	1.0	1EL1186	9223B-QT	CLJ	12/22/21 16:45	
1EL2092-03 River Gate				Matrix:Drink Wtr		Collected: 12/22/21 09:30	
Total Coliforms	<1.0 MPN/100ml	1.0	1EL1186	9223B-QT	CLJ	12/22/21 16:45	
E. Coli	<1.0 MPN/100ml	1.0	1EL1186	9223B-QT	CLJ	12/22/21 16:45	
1EL2092-04 Rutherford				Matrix:Drink Wtr		Collected: 12/22/21 09:39	
Total Coliforms	<1.0 MPN/100ml	1.0	1EL1186	9223B-QT	CLJ	12/22/21 16:45	
E. Coli	<1.0 MPN/100ml	1.0	1EL1186	9223B-QT	CLJ	12/22/21 16:45	
1EL2092-05 Clayton/Hold Bridge				Matrix:Drink Wtr		Collected: 12/22/21 09:42	
Total Coliforms	<1.0 MPN/100ml	1.0	1EL1186	9223B-QT	CLJ	12/22/21 16:45	
E. Coli	<1.0 MPN/100ml	1.0	1EL1186	9223B-QT	CLJ	12/22/21 16:45	

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety. Samples were preserved in accordance with 40 CFR for pH adjustment unless otherwise noted. MRL= Method Reporting Limit.

City of Lee's Summit - Public Works Dept.
220 SE Green Str
Lees Summit, MO 64063

December 23, 2021

Work Order: 1EL2092

Page 2 of 3

Certified Analyses included in this Report

Method/Matrix	Analyte	Certifications
9223B-QT in Drink Wtr		
	Total Coliforms	KS-KC,MO-KC
	E. Coli	KS-KC,MO-KC

Code	Description	Number	Expires
KS-KC	Kansas Department of Health and Environment-KC	E-10110	04/30/2022
KS-NT	Kansas Department of Health and Environment (NELAP)	E-10287	10/31/2022
MO-KC	Missouri Department of Natural Resources	140	04/30/2022
SIA1X	Iowa Dept. of Natural Resources (updated certificate pending)	95	02/01/2024

End of Report



Keystone Laboratories, Inc.

Carolyn Jackson
Project Manager

Keystone

205 E VanBuren St
Centerville, IA 52544
Phone: 641-437-7023
Fax: 641-437-7040

PAGE _____ OF _____

PHONE:

FAX: 016-201-7116

Keystone Quote No:

1512092

Dr. Huo C.

LABORATORY
SAMPLE
NUMBER

SAMPLE CONDITION/COMMENTS

15-2092-01

0.0

06

20

Contact Lab Prior to Submission

Remarks:

Date	12/22/21
Time	3:28

Boundary Snap

11

140 W. 42nd St

100% correct

005-122