

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20213681
Address: 2150 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Michael Harkins	Failed	Tuesday, February 15, 2022

Corrective Action Required:

1

Corrective Action Required:

2	FIRST FLOOR	- 2/15/22 BLDG 2 AREA A SHEAR WALLS 1 & 2 PROVIDE NAILING PER SHEARWALL NAILING SCHEDULE ON PLANS -
---	-------------	--

Corrective Action Required:

3 SECOND FLOOR

Corrective Action Required:

4 THIRD FLOOR

Comments: