

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20215409  
Address: 940 NW PRYOR RD, Unit:A, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>In-wall Inspection</b>	Michael Harkins	Partial	Tuesday, February 15, 2022

**Corrective Action Required:**

1	Misc	-Seal all through floor penetrations ( floor sinks & floor drains ) with approved material - Provide access panel gas shutoff south wall near floor sink
---	------	---

**Comments:**