CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20191614

Address: 1701 SE OLDHAM PKWY, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Occupancy Inspection - Codes Robb Popp Failed Wednesday, February

Commercial 16, 2022

Informational:

1 Miscellaneous All residential units and common spaces in buildings A,B and C, and kitchen

Correction 164 approved with codes

-ok to occupy when approved by other departments

Corrective Action Required:

2 Miscellaneous -Complete all items for all other departments

Correction -Provide Health Dept approval from Jackson County for swimming pool

-Complete all sight lighting and receptacles at lights-bond poles to ground

rod

-Install louvered covers for fresh air at rooftops

Comments: