

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212857

Address: 3807 SW WALSH DR, LEES SUMMIT, MO 640823803 SW WALSH DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Wednesday, February 16, 2022

Corrective Action Required:

1	Misc	3803 OK TO INSULATE
		3807
		-fireblock HVAC/plumbing chase at garage
		-fireblock between top plate and air gap at rated wall 2nd floor, air gap open to attic space above
		-Have engineer address prescribed fix for rated rock to roof decking, no C channel per design and gaps between rated plywood and rated

Comments: