

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20211943  
Address: 2358 SW OLD PORT RD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mitchell Schwarz	Failed	Thursday, February 17, 2022

Corrective Action Required:

1	Misc	-fix electrical next to garage entry -fire block above fridge -complete gas line bonding -fire block furr down ends in basement -fire block vertically every 10' horizontally -double joist hanger (2) basement -fire block around egress window -complete upstairs laundry double wall attach water and move electrical -sold block sheathing breaks at back wall 2nd floor FOAM GAPS
---	------	--

**Comments:**