

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20215974	Date:	February 17, 2022
Project Title:	SAINT LUKES EMERGENCY ROOM - OFFICE AND CT ROOM	Applicant:	
Location:	80 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086	JAYHAWK FIRE SPRINKLER CO INC	12030 S HEDGE LANE TERRACE
Type of Work:		OLATHE, KS 66061	
Occupancy Group:	I-2	Primary:	(913) 422-3770
Description:	INTERIOR ALTERATIONS TO EMERGENCY ROOM AREA - RENOVATING/REMOVING EXISTING OFFICES TO CREATE OFFICE AND CT ROOM		
Construction Type:	Type IA		
Map Page:			

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Jim Eden

Released for Construction

1. 2018 IFC 901.2- Construction documents. The fire code official shall have the authority to require construction documents and calculations for all fire protection systems and to require permits be issued for the installation, rehabilitation or modification of any fire protection system. Construction documents for fire protection systems shall be submitted for review and approval prior to system installation.

Plans received February 14, 2022.

2. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

A visual inspection will be completed at the final occupancy inspection.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.