

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211620
Address: 2329 SW OLD PORT RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Thursday, February 17, 2022

Corrective Action Required:

1 Misc

- all exterior items need to be inspected (to much snow to inspect)
- complete electrical above master bath toilet
- Secure electrical for hot water heater
- Address hvac in basement where broken/disconnected
- set screw for anti syphon device installed sheared off

Comments: