

**Attn: Mr. Joe Frogge  
City of Lee's Summit  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063**

February 14, 2022

**Re: European Wax Center, 940 NW Pryor Road Unit F, Lee's Summit MO 64081  
Permit No: PRCOM20220404**

Dear Joe Frogge,

Please find below our responses to the identified comments:

1. 2017 NEC Article 210.8 (B) Other Than Dwelling Units. All 125-volt, single-phase, 15- and 20-ampere receptacles installed in the locations specified in 210.8(B)(1) through (10) shall have ground-fault circuit-interrupter protection for personnel.
  - (1) Bathrooms
  - (2) Kitchens
  - (3) Rooftops
  - (4) Outdoors
  - (5) Sinks - where receptacles are installed within 6 feet of the outside edge of the sink.
  - (6) Indoor wet locations
  - (7) Locker rooms with associated showering facilities
  - (8) Garages, service bays, and similar areas other than vehicle exhibition halls and showrooms.
  - (9) Crawl spaces – at or below grade level.
  - (10) Unfinished portions or areas of the basement not intended as habitable rooms.  
(refer to code for exceptions)

Action required: Modify drawings to show that all receptacles within 6' of a sink will be GFCI protected.

RESPONSE: Note added to drawing E-002 and GFCI indicated on required outlet on power plan E-102.

If there are any questions, please let us know.

Yours Sincerely,  
[On behalf of Ryan Soames Engineering, DPC](#)

Michael D. San Buenaventura, P.E.  
*Associate*  
Tel: +1 (917) 720-3696  
Email: [msanbuenaventura@ryansoames.com](mailto:msanbuenaventura@ryansoames.com)