

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20213431  
Address: 420 SW LONGVIEW BLVD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Sidewalk Inspection</b>	Ronald Paynter	Partial	Monday, February 21, 2022

Corrective Action Required:

1	Misc	Forms were placed, but there is issues concerning fall of moisture. There is also a broken ADA ramp that was done by a subcontractor. Steve Davis is checking on the replacing the other ramp also and who will do the work. RP 2-21-22
---	------	---

**Comments:**