

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20215860  
Address: 1901 NE PARK RIDGE DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Pool Steel/Bonding - Residential</b>	Khanh Nguyen	Failed	Tuesday, February 22, 2022

Corrective Action Required:

1	Misc	Bonded: ladder, handrail, perimeter deck rebar
---	------	--

**\*\*must bond the pool metal shell/frame**

**Comments:**