CITY OF LEE'S SUMMIT

Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20212479

Address: 3112 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

Inspected On: Tuesday, February 22, 2022

Inspected By: Mitchell Schwarz

Expiration Date: 3/22/2022 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection: Outcome: Date:

Occupancy Inspection - Mitchell Schwarz Temporary C of O Tuesday, February

Codes Residential 22, 2022

Corrective Action Required:

1 Misc TCO UNTIL 3/22/22

-sod

-check water meter and siding from ground at time of sod -splash blocks and sump pump discharge to extend 36" from

foundation

-obtain lawn irrigation permit