

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20214591
Address: 1103 SW OLDHAM PKWY, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection	Michael Harkins	Failed	Tuesday, February 22, 2022

Corrective Action Required:		
1	Miscellaneous Correction	PROVIDE GROUNDING ELECTRODE SYSTEM PER PLAN WATER SERVICE ENTRY, BUILDING STEEL, CONCRETE ENCASED ELECTRODE

Comments: