

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213399
Address: 2938 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Robb Popp	Failed	Tuesday, February 22, 2022

Corrective Action Required:

2	DCM3 ESC REQUIRED 2 DAY	-2-22-22 REQUESTED INSPECTION(S) DENIED DUE TO DEFICIENT EROSION CONTROL INSTALLATION. -INSTALL EROSION CONTROL METHODS AT PERIMETER, INSTALL GRAVEL FILTER, MIN. 6" LIFT OF 3/4' GRAVEL, CLEAN SILT AND DEBRIS FROM STREET -EROSION CONTROL REQUIRED. EROSION CONTROL SHALL BE IN COMPLIANCE WITHIN TWO BUSINESS DAYS.
---	----------------------------	---

Comments: