

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213399
Address: 2938 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Robb Popp	Not Ready	Tuesday, February 22, 2022

Corrective Action Required:

1	Misc	2-22-22 **NOT READY REQUESTED INSPECTION(S) DENIED DUE TO DEFICIENT EROSION CONTROL INSTALLATION. -INSTALL EROSION CONTROL METHODS AT PERIMETER, INSTALL GRAVEL FILTER, MIN. 6" LIFT OF 3/4' GRAVEL, CLEAN SILT AND DEBRIS FROM STREET. NO FURTHER INSPECTIONS UNTIL EROSION CONTROL IS IN COMPLIANCE
---	------	---

Comments: