

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212850
Address: 2102 SW RUTHERFORD DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Tuesday, February 22, 2022

Corrective Action Required:

1	Misc	-fireblock bump out at basement den, move electrical box , secure NM -bath exhaust fan required at basement bath -secure NM every 4.5' through furred down
---	------	--

****OK TO INSULATE****

Comments: