

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213320
Address: 3121 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Tuesday, February 22, 2022

Corrective Action Required:

1 Misc

- address studs not full length front garage corner
- strike plate at NM N garage corner
- truss hangers per plans in garage, bed 5, and at covered patio
- fire block hvac chase right of fridge into furr down in garage

Comments: