CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212062

Address: 2105 NW ASHURST DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Erosion Control Michael Harkins Failed Friday, February 11,

2022

Corrective Action Required:

1 DCM2 ESC DEFICIENT EROSION CONTROL INSTALLATION. NO FURTHER INSPECTIONS

DEFICIENT UNTIL ADEQUATE EROSION CONTROL PROVIDED.

INSTALLATION

MAINTAIN SILT FENCE MAINTAIN GRAVEL FILTER

CLEAN STREET

Comments: