

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20213404  
Address: 2118 SW RUTHERFORD DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Electrical Service Inspection</b>	Patrick Schonfeldt	Passed	Thursday, February 03, 2022

Corrective Action Required:

1	Misc	-REPLACE ACORN STYLE CLAMP FOR GEC TO UFER TO ONE THAT IS RATED FOR REBAR CONNECTION SEPARATION
---	------	---

**Comments:**