

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20214074  
Address: 420 NW KAYLEA CT, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:            | Inspector:         | Outcome: | Date:                        |
|------------------------|--------------------|----------|------------------------------|
| <b>Erosion Control</b> | Patrick Schonfeldt | Failed   | Wednesday, February 23, 2022 |

Corrective Action Required:  
2 Misc -Address erosion control at front of lot, maintain silt fence and clean all mud at front of lot in street

**Comments:**