

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20210753
Address: 213 NW AMBERSHAM DR, LEES SUMMIT, MO 64081
Inspected On: Wednesday, February 23, 2022
Inspected By: Michael Harkins
Expiration Date: 04/15/2022

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

| Inspection: | Inspector: | Outcome: | Date: |
|---|-----------------|------------------|---------------------------------|
| Occupancy Inspection - Codes Residential | Michael Harkins | Temporary C of O | Wednesday, February 23, 2022 |

Corrective Action Required:

| | | |
|---|-----------------------------|---|
| 1 | Miscellaneous Correction | PAY NOT READY FEE OBTAIN LAWN IRRIGATION PERMIT & SUBMIT BACKFLOW CERTIFICATION PROVIDE SOD PROVIDE SPLASH BLOCKS SUMP SHALL DISCHARGE 36" FROM FOUNDATION |
|---|-----------------------------|---|