

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204939
Address: 2115 NW KILLARNEY LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Service Inspection - Residential	Michael Harkins	Failed	Tuesday, February 22, 2022

Corrective Action Required:

1	Miscellaneous Correction	INSTALL GAS LINES PROVIDE GUAGE WITH MIN 10 PSI FOR 15 MIN - 2/22/22 only 5 PSI FAILED -
---	--------------------------	---

Comments: