

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211173
Address: 302 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|---------------|----------|---------------------------|
| All Rough Inspection - Residential | Shawn Hoffman | Passed | Friday, February 18, 2022 |

Corrective Action Required:

| | | |
|---|------|--|
| 1 | Misc | -CS-PF portal design per plans, see detail S4.1 in plans , nailing of siding. (3" GRID PATTERN @ LVL HEADER BREAKFAST NOOK) |
|---|------|--|

Comments: