

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215824
Address: 204 SW 3RD ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Piers/Caissons Inspection - Residential	Robb Popp	Failed	Tuesday, February 15, 2022

Corrective Action Required:

1	Miscellaneous Correction	-PROVIDE 36" MIN DEPTH THROUGHOUT -PROVIDE MIN 3" CLEARANCE AT ALL REBAR -CLEAN ALL LOOSE DEBRIS FROM BOTTOM OF FOOTING
---	--------------------------	---

Comments: