

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212062
Address: 2105 NW ASHURST DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|------------------------|-----------------|----------|------------------------------|
| Erosion Control | Michael Harkins | Failed | Wednesday, February 23, 2022 |

Corrective Action Required:

| | | |
|---|---------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 1 | DCM2 ESC DEFICIENT INSTALLATION | DEFICIENT EROSION CONTROL INSTALLATION. NO FURTHER INSPECTIONS UNTIL ADEQUATE EROSION CONTROL PROVIDED. MAINTAIN SILT FENCE MAINTAIN GRAVEL FILTER CLEAN STREET |
|---|---------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|

Corrective Action Required:

| | | |
|---|---------------------------------------|--------------------------------------------------------------------------------------------------------------------------------|
| 2 | DCM2 ESC DEFICIENT INSTALLATION | DEFICIENT EROSION CONTROL INSTALLATION. NO FURTHER INSPECTIONS UNTIL ADEQUATE EROSION CONTROL PROVIDED. CLEAN STREET |
|---|---------------------------------------|--------------------------------------------------------------------------------------------------------------------------------|

Comments: