

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20212062  
Address: 2105 NW ASHURST DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Gas Service Inspection - Residential</b>	Michael Harkins	Failed	Wednesday, February 23, 2022

Corrective Action Required:

2	Miscellaneous Correction	PROVIDE MINIMUM 10 PSI FOR 15 MINUTES FOR GAS TEST @ 0 PSI 2/23/22
---	--------------------------	--

**Comments:**