

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20215970  
Address: 4544 NE SENECA TER, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Piers/Caissons Inspection - Residential</b>	Khanh Nguyen	Failed	Wednesday, February 23, 2022

Corrective Action Required:

1	Misc	<b>**EROSION CONTROL NOT IN COMPLIANCE. TRASH BLOWN ONTO NEIGHBORS PROPERTY. NO FURTHER INSPECTION</b>
		-Piers are not sized and aligned per plan

**Comments:**