

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20215687  
Address: 220 SE GREEN ST, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	Mark Harding	Failed	Thursday, February 24, 2022

**Corrective Action Required:**

1	Misc	-Mc cable and 2 4x4 junction boxes over the south wall need to be secured. -Secure Mc cable within 12" of a box, center of the room. - light and MC supported by electrical wire. Provide approved support wire listed for use to support MC and lighting fixture. - NOTE: 2 exit signs need to be removed. one on the south door in office area and the other outside the west door in hall area. contact Mark 969-1216 if you have questions.
---	------	---

**Comments:**