


February 23, 2022

Summit Homes
120 SE 30th St.
Lee's Summit, MO 64082


**RE: Clarification of jack studs for header at Flex Room and Master bedroom for Lot # 109 Hawthorne Ridge–
3201 SW Arbortree Dr. Lee's Summit, MO 64082 – Permit # PRRES20212837**

This letter clarifies the jack studs for header at Flex Room and Master Bedroom for Lot # 109 Hawthorne Ridge.

- Girder Truss at bedroom #1 shall have (2) #2 2x4 Douglas Fir Larch studs at supports as shown in image below.



- Flex Room shall have (2) #2 2x4 Douglas Fir Larch studs at supports as shown in image below.



Sincerely,



Bradley Huxol, PE

