

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212838
Address: 528 SE DAVID RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Thursday, February 24, 2022

Corrective Action Required:

1	Misc	-upload engineer report to portal for garage suspended slab -address top plate to top plate connection as required by code, see 2nd floor 2x6 to 2x4 walls -provide stud shoes at 2nd floor bathroom studs bored for DWV on LBW -secure gas flex line above furnace -drop ceiling light box to ceiling line at HVAC furred down garage
---	------	--

OK TO INSULATE

Comments: