CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204939

Address: 2115 NW KILLARNEY LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

All Rough Inspection - Michael Harkins Failed Thursday, February 24,

Residential 2022

Corrective Action Required:

1 Miscellaneous Land conductors in a box (covered deck)

Correction Expose covered patio for inspection

(provide ladder)

Provide LIBs per plan (2 nails top & bottom plate & intersecting studs)

PROVIDE BOND ON gas line (needs clamp)

OPSION GAS GUAGE

: 2/22/22:

ENGINEER TO ADDRESS NOTCHED LVL HEADER AT BASEMENT PATIO DOOR

Comments: