



WATER UTILITIES LEE'S SUMMIT

1200 SE Hamblen Road | Lee's Summit, MO 64081

P: 816.969.1900 | F: 816.969.1935

backflow@cityofls.net | LSwater.net

Backflow Prevention Assembly Test Data & Maintenance Report

Customer New Mark Homes					
Service Address 1920 SW River Run Dr., Lee's Summit, MO 64082					
Location of Backflow Assembly on Property Front Yard by water meter.					
Date of Test 10/29/21		Time 11 : 30 AM <input checked="" type="checkbox"/> PM <input type="checkbox"/>		Supply Pressure 80 LBS	
				Air Gap (2 x Supply Diameter) Supply: _____ IN. Gap: _____ IN. <input type="checkbox"/> PASS <input type="checkbox"/> FAIL	
Type of Assembly <input checked="" type="checkbox"/> DC <input type="checkbox"/> DCD (Detector) <input type="checkbox"/> PVB* (See Bottom of Form)		Manufacturer WILKINS		Model 350	
				Size 1.0	
				Serial Number AJC 4116	
Height off Floor _____ FT _____ IN		Protection From Freezing: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Flooding: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		Supply Source <input checked="" type="checkbox"/> Public Potable Water <input type="checkbox"/> Both <input type="checkbox"/> Non-Potable Water (e.g., LAKE)	
				New Installation <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	
Initial Test			Final Test After Repair		
Reduced Pressure Principle Assembly:			Reduced Pressure Principle Assembly:		
RELIEF VALVE opened at _____ PSID (2 PSID or more)			RELIEF VALVE opened at _____ PSID (2 PSID or more)		
2nd CHECK held backpressure			2nd CHECK held backpressure		
NO. 2 SHUTOFF VALVE leak tight			NO. 2 SHUTOFF VALVE leak tight		
1st CHECK held in direction of flow _____ PSID (5 PSID or more)			1st CHECK held in direction of flow _____ PSID (5 PSID or more)		
DIFFERENCE (1st check - relief) _____ PSID (3 PSID or more)			DIFFERENCE (1st check - relief) _____ PSID (3 PSID or more)		
Note: Failure of any of the above items, requires repair.			Note: Failure of any of the above items, requires repair.		
Initial Test			Final Test After Repair		
Double Check Valve Assembly:			Double Check Valve Assembly:		
1st CHECK held in direction of flow 1.8 PSID (1 PSID or more)			1st CHECK held in direction of flow _____ PSID (1 PSID or more)		
2nd CHECK held backpressure			2nd CHECK held backpressure		
2nd CHECK held in direction of flow 2.0 PSID (1 PSID or more)			2nd CHECK held in direction of flow _____ PSID (1 PSID or more)		
NO. 2 SHUTOFF VALVE leak tight			NO. 2 SHUTOFF VALVE leak tight		
Note: Failure of any of the above items, requires repair.			Note: Failure of any of the above items, requires repair.		
Application:			Comments		
<input type="checkbox"/> Commercial <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Fire Line <input type="checkbox"/> Fire Line By-Pass **Meter # _____ **Meter Read _____ <input type="checkbox"/> Point of Use					
The Above Report is Certified to be True, Accurate and Complete					
Tested By (Print) JUAN O. VIDAL		(Signature) 		Repaired by (Print) (Signature)	
Company JV LANDSCAPE SOLUTIONS LLC.		Final Test By (Print) (Signature)		Date of Repair	
Missouri Certification Number 33-2654		Expiration Date 04/30/2022		Owner or Owner's Representative	
				Date 10/29/21	
<p>*If an existing PVB is beyond repair and needs replacement, it should be replaced by a DC or RP to meet current State and City regulations. New PVB installations or replacements are not permitted. **METER # and METER READ for the fire line by-pass meter on detector assemblies are required. Missouri State Regulation 10 CSR 60-11-010(6)(E) requires testers to report results of tests and inspections to the customer and water supplier.</p>					