

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213399
Address: 2938 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Friday, February 25, 2022

Corrective Action Required:

2	Miscellaneous Correction	<ul style="list-style-type: none">- Fire block penetration top plate pantry- Strap top plate were top plate cut for closet bedroom 2- Fire block dwv bathroom 1 exterior wall- Fire block gap above fire place blocking- Fire block fur out stairs above landing at foundation- Nail intersecting corner basement right of sliding door- Support csst basement exterior wall near hvac- Add anchor bolts to sill plate either side of basement sliding door- Vertical fire block in basement every 10' exterior walls through out- Complete nails in all LIB's- Expose portal frame
---	--------------------------	---

Comments: