

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212483
Address: 2114 NW KILLARNEY LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Michael Harkins	Failed	Friday, February 25, 2022

Corrective Action Required:

1	Miscellaneous Correction	02/25/22 -CORRECTIONS REQUIRED WITHIN 2 BUSINESS DAYS- -NO FURTHER INSPECTIONS UNTIL IN COMPLIANCE - CLEAN DEBRIS SPILLED OVER CURB LINE, PROTECT STORM INLET (SILT FENCE)
---	--------------------------	---

Comments: