

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204940
Address: 322 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|--------------------------------------|--------------|----------|---------------------------|
| Electrical Service Inspection | Mark Harding | Failed | Friday, February 25, 2022 |

Corrective Action Required:

| | | |
|---|------|--------------------------|
| 1 | Misc | tighten GC in main panel |
|---|------|--------------------------|

Comments: