

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212483
Address: 2114 NW KILLARNEY LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Plot Plan Inspection	Michael Harkins	Failed	Friday, February 25, 2022

Corrective Action Required:	
1 Miscellaneous	LOT SNOW COVERED
Correction	REMOVE TRASH & CONSTRUCTION DEBRIS
	PROVIDE SILT FENCE AT CURB INLET

Comments: