

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRCOMCOM20215136
Address: 930 NW BLUE PKWY, Unit:M, LEES SUMMIT, MO 64086
Inspected On: Friday, February 25, 2022
Inspected By: Michael Harkins
Expiration Date: 03/04/2022

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Michael Harkins	Temporary C of O	Friday, February 25, 2022

Corrective Action Required:

1	Miscellaneous Correction	PROVIDE 18" VERTICAL GRAB BAR RESTROOM PER PLAN INSULATE PLUMBING UNDER RESTROOM VANITY PER PLAN 40' MAX HEIGHT TO REFLECTIVE SURFACE RESTROOM MIRROR PER PLAN REPLACE SECURITY LIGHT ABOVE FRONT ENTRY DOOR PER LS FIRE
---	-----------------------------	--