

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20215300
Address: 500 NW CHIPMAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---------------------------------|--------------|----------|-----------------------------|
| Water Service Inspection | John Jackson | Partial | Saturday, February 26, 2022 |

Informational:
1 Misc 02/26/22 Saturday (Bair's Construction)
Contractor exposed city water main to be Tap in for the 1" service line for water meter. Orange safety fence was installed around excavated area. Contractor will run 1" blue poly water main for domestic service line. 1" tap is scheduled for next week.

Comments: